



NOTES:

1. WALLS OF ALL CATCH BASIN OVER 10 FT DEEP TO BE INCREASED TO 12" THICKNESS. INSIDE DIMENSIONS TO REMAIN THE SAME.
2. PRECAST CONCRETE TOP SHALL BE APPROVED BY THE ENGINEER BEFORE INSTALLATION.
3. CATCH BASIN SUMPS SHALL BE OMITTED IF DIRECTED BY THE ENGINEER.
4. PROVIDE 4" PVC PERFORATED WEEP PIPE TO RELIEVE THE GROUNDWATER FROM THE PIPE BEDDING. PLACE AT ALL LOCATIONS WHERE PIPE ENTERS OR EXITS THE STRUCTURE.
5. ALL GRATES SHALL BE TYPE 'A' GALVANIZED GRATES.
6. CB TOP TO BE SET ON MIN OF 2" TO MAX 4" OF MASONRY FOR ADJ.

SCALE	CITY OF TORRINGTON Engineering Department
N.T.S.	
APPROVED	TYPE "C" CATCH BASIN
RV. DATE	
JAN. 2002	
APR. 2009	
AUG. 2011	