



**NOTES:**

- BEDDING SHALL BE No.6 (3/4") CRUSHED STONE (CONNDOT FORM 816 M.01.01)
- UNSUITABLE MATERIAL BELOW NORMAL GRADE SHALL BE REPLACED WITH No.6(3/4") CRUSHED STONE (CONNDOT FORM 816, ART. M.01.01) AS DIRECTED BY THE CITY ENGINEER.
- ALL WORK MUST BE CONDUCTED IN STRICT ACCORDANCE WITH THE LATEST REGULATIONS OF OCCUPATIONAL SAFETY AND HEALTH ADMINISTRATION (OSHA) FOR EXCAVATIONS.

## TYPICAL STORM DRAINAGE TRENCH HDPE PAVED AREAS

NOT TO SCALE

**SECTION 4.4**

SCALE N.T.S.	CITY OF TORRINGTON Engineering Department
APPROVED	
RV. DATE	TYPICAL STORM DRAINAGE TRENCH HDPE PAVED AREAS
JAN. 2002	
APR. 2009	
AUG. 2011	