



**NOTES:**

1. REFER TO TYPICAL TRENCH DETAIL FOR REQUIRED PIPE BEDDING, IDENTIFICATION WARNING TAPE, AND RESTORATION REQUIREMENTS
2. MAXIMUM BEND SHALL NOT EXCEED 22.5°
3. PVC PIPE SHALL CONFORM TO ASTM D-3034 SDR 35
4. FILTER FABRIC, UTILITY

**SECTION 5.11**

SCALE N.T.S.	CITY OF TORRINGTON Engineering Department
APPROVED E.J.F	
RV. DATE JAN. 2002	SERVICE REPLACEMENT WITH NEW MAIN
JUL. 2010	
AUG. 2011	