



NOTES:

1. REFER TO TYPICAL TRENCH DETAIL FOR REQUIRED PIPE BEDDING, FILTER FABRIC, UTILITY IDENTIFICATION WARNING TAPE, AND RESTORATION REQUIREMENTS.
2. MAXIMUM BEND SHALL NOT EXCEED 22.5
3. PVC PIPE SHALL CONFORM TO ASTM D-3034 SDR 35.

SECTION 5.12

SCALE N.T.S.	CITY OF TORRINGTON Engineering Department
APPROVED E.J.F	
RV. DATE JAN. 2002 JUL. 2010 AUG. 2011	SERVICE LATERAL REPLACEMENT TO EXISTING WYE