

From: Martin J Connor
Sent: Tuesday, November 9, 2021 4:08 PM
To: hricaassociates@optonline.net; pebersol@emlawfirm.com
Cc: Lona Kirk
Subject: FW: 31 Pumping Station Road, Three Lot Subdivision

Please see Engineering comments below. Thanks, Marty

Martin J. Connor, AICP
City Planner
City of Torrington
140 Main Street
Torrington, CT 06790
860-489-2220


From: Paul Kundzins <Paul_Kundzins@torringtonct.org>
Sent: Tuesday, November 9, 2021 4:05 PM
To: Lona Kirk <Lona_Kirk@torringtonct.org>; Jeremy Leifert <Jeremy_Leifert@torringtonct.org>; Linda Orr <Linda_Orr@torringtonct.org>; Martin J Connor <Martin_Connor@torringtonct.org>
Subject: RE: 31 Pumping Station Road, Three Lot Subdivision

Engineering Comments at this time are:

1. Confirm and Provide Sight stopping distance calculations for all 3 driveways on Pumping Station Rd.
2. The watermain in Pumping Station Road is not show on the plan from Weed Rd to Deming Rd and the connection for Lot 2.
3. Show the future driveway (with grading) to the potential house for Lot 1

Paul.

*Paul Kundzins, P.E.
Deputy Public Works Director – City Engineer
City of Torrington
140 Main Street
Torrington, CT 06790
860-489-2234*

 [Chat with me on Teams!](#)