

STATE OF CONNECTICUT
DEPARTMENT OF TRANSPORTATION



memorandum

subject: Gas Station at Sam's Mart
861 Harwinton Road

City of Torrington

date: September 16, 2021

to: Mr. Jason Dismukes

Email: jason@dismukesengineering.com

from: Aron J. Steeves
Manager of Special Services
Bureau of Highway Operations

The following comments refer to the plan set entitled "MODIFICATIONS AND IMPROVEMENTS TO SAM'S MART, 861 HARWINTON ROAD TORRINGTON, CONNECTICUT, prepared by Jason Dismukes LLC., dated June 21, 2021, last revised 9/14/21.

No.	Comment	Inc.	Not Inc.
1.	It does not appear that the Route 4 entrance needs to have mountable curbing on the western radius.		
2.	The western radius at Circle driveway should be widened to accommodate the truck. It does not need to have the mountable curbing.		
3.	Show the lane and shoulder widths on Route 4 in the vicinity of the site driveway.		
4.	Submit a detail for the mountable curbing.		

Gina Greenalch

cc: Aron Steeves – Ron Ferris –